



**HAL**  
open science

## Assessing genuine flammability hazard of halogenated species for their safe processing and use: Case studies

B. Tribouilloy, G. Binotto, F. Flécheux, A. Vignes, G. Marlair

### ► To cite this version:

B. Tribouilloy, G. Binotto, F. Flécheux, A. Vignes, G. Marlair. Assessing genuine flammability hazard of halogenated species for their safe processing and use: Case studies. *Process Safety and Environmental Protection*, 2023, 174, pp.818-827. 10.1016/j.psep.2023.04.046 . ineris-04158808

**HAL Id: ineris-04158808**

**<https://ineris.hal.science/ineris-04158808>**

Submitted on 13 Jul 2023

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

# Assessing genuine flammability hazard of halogenated species for their safe processing and use: case studies

B. Tribouilloy<sup>a,\*</sup>, G. Binotto<sup>a</sup>, F. Flécheux<sup>b</sup>, A. Vignes<sup>a</sup>, G. Marlair<sup>a</sup>

<sup>1</sup>French National Institute for Industrial Environment and Risks (INERIS), Parc Technologique Alata, BP2, 60550 Verneuil-en-Halatte, France

<sup>2</sup>Laboratory for the Study and Research of Metallic Packaging (LEREM), 100 Rue Louis Blanc Les Marches de l'Oise, Montataire, France

Corresponding author.

E-mail address: benoit.tribouilloy@ineris.fr

## Abstract

It is recognized that the combustion of halogenated substances (gas and liquids) may present specific features compared to traditional hydrocarbons. As a matter of facts, the standardized flammability characterization methods referenced by the various regulations (transport, labelling, etc.) do not necessarily take the specific features of these substances into account. Subsequently, this may lead to an underestimation of the risk associated with their use (physical hazard such as explosion). Through two case studies of interest, one concerning a fluorinated liquid, the other focusing on a fluorinated gas, this work reveals technical difficulties that may arise in appraising actual flammability hazards of halogenated hydrocarbons, due to their combustion specific behavior, when applying existing flammability methods without appropriate expert judgement. In the case of the liquid ethoxy-nonafluorobutane (Novec 7200™) this work highlights that this substance can be erroneously considered non-flammable due a clear pitfall of flash point methods, whilst its genuine flammability can be revealed otherwise. Regarding gaseous halogenated species, we show that operating conditions shall be carefully selected to reveal the genuine flammability behavior of such substances. Indeed, this is not necessarily correctly identified in all possible flammability hazard rating standard methods. In this study, the application of [EN 1839 \(2017\)](#) standard allows to confirm that R1234ze(E) is flammable at temperatures below 30°C, at atmospheric pressure and at a humidity of 50%RH.

**Keywords:** halogenated substances, flammability, experimental methods, regulation

## 1. Introduction

Halogenated organic compounds (molecules containing mainly fluorine, chlorine, and bromine atoms) are either reputed 'non-flammable' (due to their strong flame retardancy properties) or hardly flammable depending on their molecular structure and more precisely their degree of halogenation. For several years now, new gases (refrigerants, propellants) and liquids (degreasing and cleaning solvents) have been made available on the market, replacing brominated or chlorinated compounds progressively banned due to their toxicity and environmental impact (more specifically, the impact on the ozone layer and the so-called global warming potential (GWP) ([Yang et al, 2012](#)). It appears that the flammability properties of these new substances are often ignored or carelessly characterized by standardized experimental methods originally calibrated for substances composed of molecules containing mainly carbon, hydrogen, and oxygen atoms and do not consider the specificities of halogenated organic compounds in terms of combustion (e.g., impact of air moisture, effect of the test volume, influence of hydrogen /halogen (H/X) molar ratio, resilience to flame propagation, etc.). Flammability hazard rating methods are for example cited in the regulations applicable for the transport of dangerous goods and for the classification and labelling of chemicals in principle transposed from the GHS ([Globally Harmonized System](#)) developed by United Nations technical committees such as the (EU) 1278/2008 Classification for labeling and packaging of Substances and mixtures (so called CLP Regulation). Therefore, these artefacts may lead to an underestimation of the genuine flammability hazard profile of halogenated substances and mixtures and the associated fire and explosion risks. In addition to a review of the available literature on the matter, the present study provides a practical insight on these problems through testing the flammability of one fluorinated gas, namely cis-1,3,3,3-tetrafluoropropene used as refrigerant, and one fluorinated liquid, the ethoxy-nonafluorobutane used as a cleaning or degreasing solvent, by applying standardized and regulatory methods. In particular, the study reveals that for gases,

the choice of the method for determining the flammability limits (FLs) is essential; and that in the case of liquids, none of the flash point methods conventionally used are suitable for assessing the actual flammability of halogenated liquids: in this latter case, other alternative but still standardized methods must be used (explosion or flammability limits (Molnarne et al., 2017) and/or Lower Explosion Point (LEP) (EN 15794, 2009), also known as Lower Temperature Flammability Limit (LTFL) (ASTM E1232, 2019).

GHS and parent CLP classification schemes define a gas and gas mixture as flammable if it has a flammability range at 20°C and 101.3 kPa in air. In the absence of available data on the flammability of a gas, these two legislations refer to standard ISO 10156 (2017) proposing an experimental method to define the flammability potential (flammable or non-flammable) of a gas or gas mixture of gases. However, this document indicates that "*the compressed air must be analyzed and have a moisture content of less than or equal to 0.01%*", i.e., the test shall be performed with use of dry air. This moisture-free air requirement for assessing gas flammability property originally aims at determining the most severe flammability constraints in a general manner. However, it does not reflect current scientific evidence of the actual impact of humidity on the flammability of halogenated organic compounds, although well-established since a decade (Kondo et al, 2012, 2014). In GHS text, it is specified that the competent authorities may use an equivalence method in the absence of sufficient data. The European Chemicals Agency (ECHA) guidance on the application of CLP regulation (Regulation (EC) No 1272/2008) also cites European standard EN 1839 (2017) as relevant to determine the FLs of a gas for its classification among one of the "flammable gas" hazard categories. Worth to notice, in the appendix, this standard proposes an experimental method specifically adapted to hardly flammable substances (including halogenated organic compounds). It states: "... *it is necessary to establish a relative humidity of the air of 50% (measured at room temperature) for halogenated hydrocarbons having a degree of halogenation greater than 0.8*". Regarding regulatory texts, a gas can be classified as non-flammable by reference to ISO 10156 (2017) and still have a flammable range according to EN 1839 (2017), due to discrepant requirements about the relative humidity of the air (dry or humidified) in the underpinning testing protocols of the mentioned standards. When dealing with emerging refrigerants, of which many are halogenated, flammability assessment is often carried out according to other standards, i.e., ANSI/ASHRAE-34 (2019) or ISO 817 (2014). In these latter, the flammability assessment is based solely on the lower flammability limit (LFL) determined in the test apparatus described in the American standard ASTM E681-09 (2015). This latter test protocol also requires that moisture air having a relative humidity (%RH) of 50% need to be used.

More problematic than halogenated gases are halogenated liquids whose formal classification in the category "flammable liquid" in the context of hazmat regulations are based on both the flash point and the boiling point. New cleaning and degreasing solvents have been developed in recent years to timely replace those that no longer meet newly worldwide established targets regarding safe (reduced flammability and toxicity) and environment-friendly chemicals (not promoting greenhouse gases emissions or ozone depletion contributors), such as trichloroethylene and n-propyl bromide banned for their toxicity. Among the physical hazards to be assessed, the flammability of liquids is mainly defined in official hazard classification schemes by the flash point. However, the existing standard methods for measuring flash points are not suitable for many halogenated liquids, which sometimes results in an underestimation of the fire and explosion risks associated with these chemicals. Subsequently this may result to a misleading understanding of the apparent 'non-flammable' character because of conventional hazard classification. In fact, the absence of the hazard statement "flammable" on the SDS or on the bottle (pictogram) does not mean that the contained liquid is unable to generate vapours that can be ignited, in mixture with air, by a sufficient source of ignition. Some liquids or mixtures of liquids do not have a flash point but can nevertheless generate explosive atmospheres (ATEX) due to the existence of a flammability range determined with the appropriate method (EN 1839 (2017), ASTM E681-09 (2015)). For halogenated liquids, flammability may not be correctly assessed by using flash point measurement methods because the volume of the test vessel is too small compared to the flame extinction distance of these vapours and is not suitable. For this type of liquid, ASTM E502-07 (2013) advises to determine the lower flammable temperature limit (LFTL), (ASTM E1232 (2019)) equivalent to the lower explosion point (LEP), EN 15794 (2009). Clearly, the flammability range of vapours generated by a liquid would also be a parameter to consider.

As a further step to what was recently published by Tribouilloy et al (2022), as well as by some rare pioneering teams, we address this issue in a practical way by further testing one fluorinated liquid with various methods targeting the evaluation of the flammability hazard, as case studies. These case studies

were selected for both the emerging interest for their use and existence of previously published works that allow for some useful comparisons.

## 2. Flammability of gases according to EU, US, and international standards

Table 1 shows the specifications of the European (proposed by the European Committee for Standardization – TC 305/WG1), American (proposed by American Society for Testing and Materials) and the International Organization for Standardization (ISO) methods used by the various regulations to classify gases in terms of flammability. The flammability of a substance depends not only on its intrinsic properties but also on the procedures applied. For gases, the US (ASTM) and EU (EN) standards are quite different in terms of test equipment, protocols, and ignition criteria (Molnarne et al., 2017; Brandes et al., 2008).

**Table 1**

Different experimental methods for the classification of flammable gases

Standards	ASTM E681-09	EN 1839-T	EN 1839-B	ISO 10156	EU Test A.11
Date	2015	2017	2017	2017	2008
Test vessel	Flask, spherical V= 5 dm <sup>3</sup> cf Annex A1 for substances which may be difficult to ignite V = 12 dm <sup>3</sup>	Clear tube (glass or polycarbonate) Ø = 80 mm, H ≥ 300 mm cf Annex A for substances which may be difficult to ignite H = 500 mm	Closed sphere or cylinder H/Ø = 1 to 1.5, V > 5 dm <sup>3</sup>  The bomb method has been found to be unsuitable substances which may be difficult to ignite	Glass tube Ø ≥ 50 mm H ≥ 300 mm	Glass tube Ø ≥ 50 mm H ≥ 300 mm
Used in this work ?	No	Yes	Yes	Yes	Yes
Ignition source	Induction spark (duration 0,2s and 0,5s) or fuse wire	Induction spark (duration 0,2s)	Induction spark (duration 0,2s) or fuse wire (E between 10J and 20J)	Induction spark (duration 0,2s and 0,5s / E = 10J)	Induction spark (duration 0,5s)
Criterion for ignition	Flame visually propagates upward and outward from the ignition point, with arc > 90°	Visual, flame detachment > 100 mm or aureole H > 240 mm from the spark gap	Pressure increase ≥ 5% + ignition pressure in air	Visual, 100 mm flame detachment from the spark gap	Visual, Flame detachment
Increment	Freely selectable, to be specified in report if x > 10% (rel.) of the test substance fraction	10% (rel.) to 0.2 mol% (abs.), depending on the test substance fraction	10% (rel.) to 0.2 mol% (abs.), depending on the test substance fraction	0.1% by volume for FL < 10% and 0.2% by volume for FL ≥ 10%	Not specified
Number of repetition test	1	4	4	4	Not specified
Oxidizer	Room air or air cylinder with O <sub>2</sub> = 20,94% vol ± 0,1%vol	Air, which must be water-free or synthetic air		Compressed air must be analysed and have a	Air

RH of air: 50%  
for substances  
which may be  
difficult to ignite

RH of air: 50%  
for substances  
which may be  
difficult to ignite


/  
moisture  
content of  
0.01% or less

Only [EN 1839 \(2017\)](#) and [ASTM E681-09 \(2015\)](#) standards consider the specificities of difficult-to-ignite substances with large quenching distances, including ammonia, amines, and partially halogenated compounds, as well as mixtures containing high proportions of these substances.

### 3. Case studies

#### 3.1. 1,3,3,3-Tetrafluoropropene and its arguable flammability

1,3,3,3-tetrafluoroprop-1-ene ([Fig 1](#)) is a hydrofluoroolefin (HFO) also identified as trans-,3,3,3-tetrafluoroprop-1-ene or R1234ze(E) and cis-,3,3,3-tetrafluoroprop-1-ene or R1234ze(Z).



**Fig.1.** The HFO-1234ze isomers: (E) left and (Z) right  
([https://pubchem.ncbi.nlm.nih.gov/compound/1\\_3\\_3\\_3-Tetrafluoroprop-1-ene](https://pubchem.ncbi.nlm.nih.gov/compound/1_3_3_3-Tetrafluoroprop-1-ene))

Among other emerging applications (as a gas propellant or a refrigerant component), R1234ze(Z) can also be used in specific applications like high temperature heat pumps, whereas R1234ze(E) will show operating conditions and applied costs in line with R-134a (1,1,1,2-tetrafluoroethane) according to system and compressor sizes.

A specific safety classification for refrigerant use also exists, where R1234ze(E) is classified as A2L (slightly flammable) as derived from the international standard [ISO 817 \(2014\)](#), which is referenced by [ANSI/ASHRAE-34 \(2019\)](#) and [ASTM E681-09 \(2015\)](#). This classification means the absence of a flammability range at 23°C and 101,3 kPa using the method described in Annex B of [ISO 817 \(2014\)](#), more precisely described in [ASTM E681-09 \(2015\)](#) (one of the four conditions to be met in addition to the criterion of propagation of flame at 60°C with LEL >0.10 kg/m<sup>3</sup>, heat of combustion, and the optional burning velocity measurement). Significant controversy has however paved the market development of this gas, which was proposed as a replacement of R-134a, subsequently raising concerns to define safe handling and processing practices for its use ([Bellair et al, 2019](#)). The debate was raised by the application of different operating conditions and due to the strong impact of relative humidity characteristics of the air used as the oxidant for performing the tests


In their review paper, [Bellair et al, \(2019\)](#) reported that according R1234ze(E) was not rated as flammable at 20°C because of a study making use of [ISO 10156 \(2017\)](#) and A.11 European test protocol ([REGULATION \(EC\) No 440/2008](#)) with dry and moist air. In this same study, the determination of the flammability limits of R1234ze(E) was carried out at 25°C according to the [ANSI/ASHRAE-34 \(2019\)](#) method (i.e., with a spherical volume of 12 liters and not 5 liters, for reasons of quenching distance) ([Richard, 1998](#)). The FLs obtained were respectively 5.7%(vol) and 13.3%(vol) under ambient conditions. It was shown ([Kondo et al.,2012](#)) by applying the same method that from 10%RH of the air corrected to 23°C, R1234ze(E) become flammable at 35°C. At this temperature, with 50%RH, flammability of R1234ze(E) ranges from 5.95%vol to 12.7%vol and from 6,2%vol to 12.4%vol at 20°C. The application of US standards has highlighted that R1234ze(E) reveals to have a flammability range even under ambient conditions (i.e., atmospheric pressure, between 20°C et 25°C). Considering these different results, it was decided to complement these results by carrying out tests according to the method described in Annex A of [EN 1839 \(2017\)](#). Others were carried out in the tubes described in [ISO 10156 \(2017\)](#) and the method proposed by the European test A.11 with air having a relative humidity of 50%RH. Additional tests were carried out in a 20 dm<sup>3</sup> sphere to compare the results with those obtained with conventional methods.

The objectives of these tests were not only to ensure that we were able to retrieve the published data (Bellair et al 2019) from the tests derived from the European regulation, but also to highlight a possible influence of volume of the test on the flammability of R1234ze(E) by applying the standards mentioned regulation and proposed by the working group of the European Committee for Standardization (CEN TC 305 WG1).

### 3.1.1. Experimental study

#### 3.1.1.1. Test devices and procedures

The experimental set-up for the tube tests is shown in Fig. 2.




**Fig. 2.** Schematic diagram of the test set-up for the application of the glass tube method (Annex A EN 1839, 2017)

A cylinder of compressed air (1) (Supplier: Air Liquide, product ALPHAGAZ 2) and a cylinder of R1234ze(E) (Supplier: INVENTEC) (2) are connected to a 1 dm<sup>3</sup> pressure-resistant stainless-steel cylinder vessel (3). It is equipped with a magnetic stirrer (4), a 50 bar piezoresistive pressure sensor (manufacturer KISTLER, Type 4045A50) and a thermocouple (type K). In this 1 dm<sup>3</sup> cylinder the test mixture air/R1234ze(E) is prepared at approximately 30 bar by the partial pressure method (Wu et al, 2014) at room temperature. This method makes it possible to define the composition of the mixture provided those gaseous components are assumed to follow the law of perfect gases, whatever the test temperature, the relationship below is obtained which links the molar fraction of component *i* ( $x_i$ ) in the mixture, the partial pressure of component *i* ( $p_i$ ) in the mixture and the total pressure of the mixture ( $P_T$ ) (Equation. 3).

$$x_i = (p_i / P_T) \text{ with } \sum p_i = P_T \quad \text{Eq. 1}$$

The mixture thus prepared is then totally discharged into the test apparatus. It is passed through a first wash bottle (5) filled with glass beads and water to saturate it with moisture, then into a second (6), filled with glass beads but free of water, immersed in a thermostatic bath (7). The latter is set at the dew point temperature of the water corresponding 50%RH at atmospheric pressure. This temperature is between 12°C and 14°C. The gas flow then passes through a glass cylinder (8) equipped with a thermohydrometric probe to monitor %RH of the mixture. It sweeps from bottom to top through a vertically positioned glass tube (9) placed in an oven (10). The tube is equipped at its base with two electrodes 5 mm apart, between which inductive sparks are generated. This is obtained by means of a high-voltage transformer (11), with an effective voltage of 15 kV and a short-circuit current of 30 mA. The spark discharge time is set at 0.5 s. The outlet of the tube is connected to a flowmeter (12) to ensure the proper flow of the mixture through the whole experimental device. After discharging the full content of the 1 dm<sup>3</sup> cylinder into the tube, the mixture is allowed to stand for approximately one minute before attempting to ignite it. The mixture is deemed to be ignitable when self-sustaining combustion is observed in the tube. The tests consist of gradually varying the content of R1234ze(E) in air to define the low (LFL) and high (UFL) limit between the flammable and non-flammable range of R1234ze(E) in air.

The experimental set-up for the tests in 20 dm<sup>3</sup> sphere is shown in Fig 3.



**Fig. 3.** Schematic diagram of the test set-up for the 20L-Sphere tests (EN 1839-B, 2017)

The sphere is equipped with a K-type thermocouple, a piezoresistive pressure transducer (4045A5) for the preparation of the mixtures and a piezoelectric transducer for measuring the explosion overpressure generated by the ignition of the test mixture. Two electrodes, 5 mm apart, are positioned in the center of the sphere and connected to the same transformer described above. After evacuating the sphere, R1234ze(E) is introduced until the desired partial pressure is reached. Then ambient air is added at the bottom to about 1 bar. The moisture of the incoming air is measured. The mixture is left to rest before the ignition attempt. Ignition of the mixture is considered to have occurred when the ratio of [Maximum Absolute Explosion Pressure ( $P_{ex}$ )]/[Initial Pressure ( $P_i$ )] is greater than or equal to 1.05 (criterion defined by the EN 1839 (2017) bomb method).

#### 3.1.1.2. Flammability limits measurement: experimental results and discussion

The experimental data obtained for the determination of the FLs according to the volume used in this study (see Table 1) are listed in Table 2, Table 3, and Table 4. These tables contain all the operating conditions used in the tests, which indicate either: the composition of the mixture, the relative humidity (of the test mixture for the tube method and of the ambient air introduced for the 20-liter sphere), the temperature measured in the test volume, the flammability or non-flammability of the test mixture. The investigation of the lower (LEL) and upper (UEL) flammability limits of the respective concentration levels was carried out in a stepwise process using increments of increasing or decreasing concentration of 0.2 vol% R1234ze(E). The flammability limits are confirmed by four additional tests and are shown in bold. As a result of this procedure, the flammability in air of R1234ze(E), determined in the tubes described by the regulatory standards ISO 10156 (2017)/EU Test A11, was found to be between 5.6 %vol and 12.0 %vol (Table 2).

**Table 2**

Flammability limit of R1234ze(E) in moist air in the tube described in [ISO 10156/E.U Test A.11](#)

<u>R1234ze(E)</u> <u>content</u> <u>in air (%vol)</u>	<u>%HR of mixture</u>	<u>Test temperature</u> <u>(°C)</u>	<u>Ignition?</u>
5,0	57	23	No
6,0	50	24	Yes
5,0	51	25	No
5,8	52	25	Yes
<b>5,6</b>	<b>54</b>	<b>25</b>	<b>No</b>
<b>5,6</b>	<b>53</b>	<b>25</b>	<b>No</b>
<b>5,6</b>	<b>53</b>	<b>24</b>	<b>No</b>
<b>5,6</b>	<b>52</b>	<b>24</b>	<b>No</b>
<b>5,6</b>	<b>49</b>	<b>25</b>	<b>No</b>
12,8	52	23	No
12,4	49	24	No
<b>12,0</b>	<b>51</b>	<b>24</b>	<b>No</b>
11,0	52	25	Yes
11,3	53	25	Yes
11,8	49	24	No
11,6	49	25	Yes
11,8	52	25	Yes
<b>12,0</b>	<b>53</b>	<b>25</b>	<b>No</b>
<b>12,0</b>	<b>52</b>	<b>25</b>	<b>No</b>
<b>12,0</b>	<b>53</b>	<b>24</b>	<b>No</b>
<b>12,0</b>	<b>51</b>	<b>25</b>	<b>No</b>

From the results obtained by applying [ISO 10156 \(2017\)/EU Test A.11](#) with a humidified mixture, we therefore observed that R1234ze(E) is flammable under ambient conditions.

From the test results, we can conclude that adopting [ISO 10156 \(2017\)/ EU Test A.11 testing protocols](#) where the test mixture is humidified highlights that R1234ze(E) is flammable in air under ambient conditions.

Applying the same procedure to screen the flammability limits of R1234ze(E) but referring to testing method defined in [EN 1839 / Annex A](#), the flammability range lies between 5.4%vol and 13.0%vol. (Table 3).

**Table 3**

Flammability limit of R1234ze(E) by application of the method described in Annex A of EN 1839 (difficult to ignite gases and vapours)

<u>R1234ze(E)</u> <u>content</u> <u>in air (%vol)</u>	<u>%HR of mixture</u>	<u>Test temperature</u> <u>(°C)</u>	<u>Ignition ?</u>
5,6	48	25	Yes
<b>5,4</b>	47	25	No
<b>5,4</b>	50	25	No
<b>5,4</b>	48	25	No
<b>5,4</b>	51	25	No
<b>5,4</b>	52	25	No
5,8	54	24	Yes
13,3	53	23	No
12,5	52	23	Yes
12,6	52	24	Yes
12,8	50	25	Yes
<b>13,0</b>	51	24	No
<b>13,0</b>	51	24	No
<b>13,0</b>	51	24	No
<b>13,0</b>	52	24	No
<b>13,0</b>	53	24	No
12,8	51	24	No

These two series of tests in tubes of different volumes (in terms of internal diameter and height) confirm that R1234ze(E) is flammable under ambient conditions of pressure, temperature, and moisture. However, there is some impact of the tube size essentially on the UFL.

The flammability range determined in 20L-Sphere by application of EN 1839 (2017) (Bomb method) is between 5.8%vol and 12.8%vol. (Table 4).

**Table 4**

Flammability limit of R1234ze(E) measured in 20 dm<sup>3</sup> sphere by application of the method described in EN 1839 (Bomb method)

<u>R1234ze(E)</u> <u>content</u> <u>in air (%vol)</u>	<u>%RH of ambient</u> <u>air introduced</u>	<u>Test temperature</u> <u>(°C)</u>	<u>Ignition?</u>
6,0	55	21	Yes
4,9	55	22	No
5,4	55	23	No
<b>5,8</b>	55	22	No
<b>5,8</b>	50	22	No
<b>5,8</b>	49	23	No
<b>5,8</b>	50	22	No
<b>5,8</b>	51	23	No
10,0	57	22	Yes
12,0	60	23	No
11,1	61	22	Yes
11,6	60	22	Yes
11,8	59	23	Yes
12,0	61	23	Yes
12,2	61	23	Yes
12,6	61	23	Yes
13,0	59	23	No
<b>12,8</b>	59	22	No
<b>12,8</b>	57	23	No
<b>12,8</b>	55	23	No
<b>12,8</b>	54	23	No
<b>12,8</b>	51	23	No

For comparison, all experimentally determined FLs values in this study are reported in Table 5 with those published by other authors such as Kondo et al (2012), Bellair et al (2019), Yang et al. (2015) and Zhai et al. (2019).

**Table 5**

Flammability limits of R1234ze(E) measured by various US and European standard methods


<u>Referential</u>	<u>Moisture</u> <u>(%RH)</u>	<u>Temperature</u> <u>(°C)</u>	<u>LFL – UFL</u> <u>(%vol)</u>	<u>Range of</u> <u>flammability</u> <u>(%vol)</u>
ISO 10156/EU test A.11	49 - 57	23 - 25	5,6 – 12,0	6,4
EN1839-Tube / Annex A	47 - 54	21 - 25	5,4 – 13,0	7,6
EN 1839-Bomb / 20 dm <sup>3</sup> sphere	49 - 61	21 - 23	5,8 – 12,8	7,0
ASTM E681/ ASHRAE (Kondo et al.,2012)	50	20	6,2 – 12,4	6,2
ASTM E681/ ASHRAE (Bellair, Hood, 2019)	50	25	5,7 – 13,3	7,6
ASTM E681 / ASHRAE (Yang et al., 2015)	67 - 70	25 - 27	7,2 – 14,6	7,4
ASTM E681 (adapted) (Zhai et al.,2019)	50	25	8,7 – 13,0	4,3
ASTM E681 (adapted) (Zhai et al.,2019)	20	25	No FLs	0
ASTM E681 / ASHRAE (Yang et al.,2015)	0	25-27	No FLs	0

Table 6 shows the estimated absolute measurement uncertainties for each parameter presented in Table 5.

**Table 6**  
Estimated uncertainty of measured parameters


Measured parameter	Absolute uncertainty on the parameter
Moisture	± 1%RH
Temperature	± 2°C
Flammability Limit	± 0,5%vol

With dry air, [Yang et al \(2015\)](#) and [Kondo et al \(2012\)](#), found no evidence of a flammability range ([Fig. 4](#)). The ignition devices used in their testing protocols develop low energy levels ranging between 5J and 20J. By contrast, [Askar et al \(2018\)](#) showed that R1234ze(E) could ignite in dry air but with high ignition energies over 500 J. The flammability range observed spreads between 6.5 vol% and 12.0 vol%.



**Fig.4:** Influence of relative humidity on the flammability range of R1234ze at 23°C (adapted from [Kondo et al, 2012](#)).

It is counter-intuitive to think that the addition of moisture to the air promotes the combustion of R1234ze(E) and other halogenated substances resulting in the widening of the flammability range. The two oxidation equations, [Equation 1](#), and [Equation 2](#), associated with their enthalpy of reaction, presented in [Figure 5](#), help to understand this phenomenon ([Zhai et al, 2019](#))




The oxidation reaction in the presence of water, [Equation 1](#), is favored by a higher enthalpy of reaction than with dry air, [Equation 2](#). The water molecule allows the fluoride radicals to be trapped to form HF and avoid the formation of COF<sub>2</sub> and other non-flammable fluorinated molecules.

R1234ze(E) is therefore flammable under ambient conditions (pressure, temperature, humidity) as shown by the results obtained by American or European standards, where the use of humid air is recommended for difficult-to-ignite substances. Moreover, the measured FLs are essentially the same, while the procedures, devices and flammability criteria are very different. However, this flammability can be superficially eliminated by applying the [ISO 10156 \(2017\)](#) standard, cited by the [GHS regulation](#), and using dry air ([Kondo et al.,2012](#)). On the other hand, according to the European CLP regulation, based on flammability limits, R1234ze(E) should be classified as a category 1 flammable gas (i.e., extremely flammable).

### 3.2. Ethoxy-nonafluorobutane: a 'non-flammable' liquid unexpectedly revealing some explosive atmosphere hazard at low temperature

The application of the various flash point determination methods for testing the flammability hazard rating of halogenated liquids may result in negative errors, since the ignition criterion, defined as being a flame propagation phenomenon on the liquid surface (so-called "flash") cannot be observed due to test configuration limitations (size effect). However, two other flammability related safety parameters can be used to assess the flammability potential of these liquids: the LEP (Brandes et al., 2007) or/and the LFL. We have illustrated this with experimental work on ethoxy-nonafluorobutane (a fluorinated degreasing solvent whose flash point is reputed non defined according to published material safety data sheets (3M Company) and therefore classified as 'non-flammable' according to CLP).

The ethoxy-nonafluorobutane (trade name: Novec® 7200, manufacturer: 3M Company) is a hydrofluoroether (Tsai, 2005) of formula  $C_4F_9OC_2H_5$ , delivered as mixture of two inseparable isomers (Fig. 5) with essentially identical properties.



**Fig 5.** The two isomers of ethoxy-nonafluorobutane: a) ethyl nonafluoroisobutyl ether (cas n°163702-06-5), b) ethyl nonafluorobutyl ether (cas n°163702-05-4) (<https://pubchem.ncbi.nlm.nih.gov/>)

Ethyl nonafluoroisobutyl ether has no flash point and ethyl nonafluorobutyl ether has a flash point of 39°C (Pubchem)

Published flammability data from a major supplier are reported in Table 7.

**Table 7**

Reported flammability volatility and flammability parameters of ethoxy-nonafluorobutane (NOVEC 7200 trademark, 3M product information 2023)

Name	Boiling (°C)	Flash Point	Flammability Range in Air (%vol)
ethoxy-nonafluorobutane	76°C	None	2,4 – 12,5

#### 3.2.1. Experimental study

##### 3.2.1.1. Flash point

It is important to observe carefully the ignition process and potential flame propagation phenomenon on the surface of the sample when the flame used as an ignition source is brought close to the surface of the liquid being tested during determination of the flash point,. For this purpose, the Cleveland open-cup apparatus described in ISO 2592 (2000) was selected for testing ethoxy-nonafluorobutane. Since only open-cup type of flash point apparatuses may allow this observation. As the flame passes over the surface of the liquid, it grows with the temperature of the liquid (so called "halo"), without spreading a flame over the surface of the liquid (Fig.6).



**Fig 6.:** Pilot flame above the liquid ethoxy-nonafluorobutane at a temperature of 32°C

Gorbett et al (2004) refer to this phenomenon as “outgassing” which also occurs with closed cup flash point methods (see Fig. 3 and Fig.7 in Gorbett et al paper), however, the non-propagation of the flame onto the surface of the test liquid in this work was hardly visible due to the type of test vessel used.



“Outgassing” can mask the true flammable nature of a substance when it occurs during the flash point test. Gorbett et al (2004) confirm that products containing certain hydrocarbons, such as dichloromethane, are capable of producing dangerously flammable atmospheres, without exhibiting formally a flash point, and are therefore not classified as flammable. Moreover, in the American guidance document, for the selection of closed cup flash point methods (ASTM E502-07, 2013), it is stated that some liquids, such as trichloroethylene, cannot propagate the flame due to the small volume of the test vessels (about 10 cm<sup>3</sup>). It should be noted that similar issues have been addressed previously for mixtures of flammable liquids containing a chlorinated liquid fraction (trichloroethylene and methyl chloride) (Rybicky et al, 1981), (Fayet et al, 2019).

### 3.2.1.2. Alternative methods for characterizing the flammability of a liquid

#### 3.2.1.2.1. Tests devices and procedures

LEP is the term used in the European standard EN 15794 (2009), whilst the American standard ASTM E1232 (2019) uses the term LFTL. These two terms are synonymous since they are consistently defined as the minimum temperature at which a liquid gives off enough vapour to form a flammable mixture with air under equilibrium conditions.


In this work, the LEP of ethoxy-nonafluorobutane was determined according to the method described in EN 15794 (2009), that is making use of a glass tube of 100 mm inner diameter and of 290 mm height. The temperatures of the liquid and gas phases are measured by type K thermocouples of 1 mm diameter (marked 1 and 2 on Fig. 7a). A third 0.5 mm diameter K-type thermocouple (3) placed just below the lid allows early detection of any temperature rise. About 10 mm above the surface of the liquid, two stainless steel electrodes (4) are placed opposite to each other at 5 mm. These electrodes are connected to a high voltage transformer (5) (effective voltage between 13kV and 16kV and short circuit current between 20 mA and 30 mA). A magnetic bar is added to stir the liquid (6). This tube is placed in a climate chamber capable of varying from -20°C to 200°C. The duration of the arc generated between the two electrodes is set at 0.2 s and 0.5 s if the first attempt is negative (no ignition).



**Fig.7:** a) Schematic diagram of the setup described in EN 15794, b) a view of the tube

The LEL of ethoxy-nonafluorobutane was determined by applying the method described in Annex A of EN 1839 (2017), for substances that are difficult to ignite due to large quenching distances but also their ability to generate flame inhibitors during combustion. For halogenated hydrocarbons with a degree of halogenation greater than 0.8, the explosion limits and limiting oxygen concentration shall be determined with moist air (50 %RH at ambient temperature) to avoid the formation of flame inhibitors (such as  $\text{COF}_2$ ,  $\text{CF}_3\text{H}$ ,  $\text{C}_2\text{F}_5\text{H}$ , etc.) through the formation of hydrogen fluoride, which testing condition was indeed applied for testing ethoxy-nonafluorobutane, since this chemical has a degree of halogenation equal to 1.8.

The tests are performed in a vertical glass tube (marked 1 on Fig.8) of 80 mm inner diameter and 500 mm height (for standard gases, the tube can be 300 mm high). At its base, 60 mm from the bottom, the same electrodes (2) described in paragraph 2.3 are connected to the same high voltage transformer (3). At the top and bottom of the tube are two 1 mm diameter type K thermocouples (4) (5). The base of the tube is connected to an evaporator (6) for the evaporation of the liquid to be tested. Between the two pieces of equipment, a pneumatic valve (7) is installed to direct the air/vapour flow towards the test tube or the evacuation (to avoid stopping the flowmeter between two tests, thus ensuring the stability of the air/vapour mixture). The assembly is placed in an oven (8). The composition of the air/steam gas mixture is prepared by flow measurement. The air flow rate is adjusted with a mass flow controller (9) and the liquid with a syringe pump (10). The air flow is saturated with water by bubbling through a flask (11) containing glass beads and filled with water. At its exit, the air stream is sent to an identical flask (12), without water, placed in a cooling bath (13) whose temperature is adjusted to achieve a relative humidity of 50% (as determined at room temperature) at its exit (marked (14) on Fig.8).



**Fig.8.** Schematic diagram of the setup described in annex A of EN 1839 - Tube method

3.2.1.2.2. *Experimental results and discussion*  
 3.2.1.2.2.1. *LEP measurement*


The tests were carried out with a filling rate of 20% by volume. The results obtained of ethoxy-nonafluorobutane sample are reported in Table 8. This first test is primarily used to determine whether liquid ethoxy-nonafluorobutane can generate vapours which, when mixed with air, can be ignited by an ignition source. Ignition is occurring at a liquid phase temperature of 7.5°C. A second test with a second sample was performed to confirm the first value obtained. Ignition was observed at 3.3°C (no ignition at 3.0°C). Fig.10 shows the development of the flame in the test vessel (video captures).

**Table 8**  
 LEP determination of ethoxy-nonafluorobutane

First sample for estimation											
Liquid phase temperature $T_{liq}$ (°C)	- 8,9	- 7,7	-5,9	- 4,8	- 2,3	0,1	1,7	3,4	5,6	6,7	7,5
Gaseous phase temperature $T_{gas}$ (°C)	- 10,5	- 8,5	- 6,6	- 4,5	- 2,6	- 0,7	1,2	3,2	5,2	4,2	5,5
$\Delta T$ (°C) *	1,6	0,8	0,7	0,3	0,3	0,8	0,5	0,2	0,4	2,5	2,0
Ignition?	No	No	No	No	No	No	No	No	No	No	Yes
Second sample for confirmation											
Liquid phase temperature $T_{liq}$ (°C)	3,3	2,7	3,0								
Gaseous phase temperature $T_{gas}$ (°C)	1,7	1,7	2,1								
$\Delta T$ (°C)	1,6	1,0	0,9								
Ignition?	Yes	No	No								

\*  $\Delta T$ (°C) is the absolute value of the difference between  $T_{liq}$  and  $T_{gas}$

The development of the flame in the test vessel is clearly visible (video captures – Fig. 9) when the test is performed at 3.3°C.



**Fig. 9.** LEP: Flame development (left to right) in the gas phase (liquid temperature: 3.3°C) after spark generation


This is a self-sustaining combustion phenomenon (flame detachment, ignition criterion) and not a halo phenomenon as in the case of the flash point ignition test. It should be noted that prior to these tests targeting the assessment of LEP of the studied chemical, other tests were carried out at higher temperatures, always with the aim of observing potential ignition. From the corresponding results presented in Table 9, this temperature range appears to correspond to the upper explosion point (UEP) zone, i.e., between 12.5°C and 17.3°C.

**Table 9**

UEP estimation of ethoxy-nonafluorobutane

Liquid phase temperature (°C)	17,3	22,7	28,5	12,5
Ignition?	No	No	No	Yes

The flame development in the test vessel (video captures – Fig.10) is observed for test performed at 12.5°C.



**Fig 10.** UEP: Flame development (left to right) in the gas phase (liquid temperature: 12.5°C) after spark generation


#### 3.2.1.2.2.2. LEL measurement

To ensure evaporation of the liquid at the evaporator outlet, we had to work at 38°C. The different concentrations of the vapours of the solvent in air tested, with a relative humidity close to 50% at ambient temperature, are presented in Table 10. The LEL is equal to 3.4%vol by applying annex A of the EN 1839 standard, with an ignition observed at 3.6%vol. (Fig. 11).

**Table 10**

LEL determination of ethoxy-nonafluorobutane in according to annex A EN 1839 / 50% RH

Concentration (%vol)	3,0	3,4	3,6	3,8
Tube temperature (°C)	38	38	38	38
Moisture (%RH)	49,7	50,2	50,9	50,9
Ignition?	No	No	Yes	Yes



**Fig 11.** LEL- Flame development (left to right) in the tube of mixture air/ ethoxy-nonafluorobutane (vapour 3,6 %vol in air) after spark generation

LEP test results for ethoxy-nonafluorobutane have shown that this chemical can generate flammable vapours in air, including at low temperatures., well below the flash point of ethanol, which is classified as "highly flammable liquid". This ability to generate explosive risks (ATEX) was confirmed by measuring its LEL according to the method described in Annex A of EN 1839 (2017) at 38°C and atmospheric pressure.

#### 4. Conclusions / recommendations

Given the particularity of halogenated substances and in particular fluorinated substances currently flooding the international market to reduce their impact on the environment (ozone layer depletion, global warming, ...), they are sometimes sold as 'non-flammable' chemicals by reference to standard methods that are not necessarily adapted to the specificities of these substances in terms of their potential implication in a combustion process, such as the influence of the relative humidity of the combustion air when dealing with a gaseous substance. For example, R1234ze(E) gas can indeed be declared as 'non-flammable' by application of [ISO 10156 \(2017\)](#) (GHS regulation), slightly flammable (according to [ASHRAE](#) standard), and even rated as "extremely flammable" by application of [EN 1839/Annex A \(2017\)](#) in the context of the European Chemicals Directive.

Even more critical is the fact that in the case of halogenated liquids, some of them although potentially falling outside of the class of flammable liquids according to international classification schemes for dangerous substances (CLP in the EU, other legal texts transposing the GHS in other parts of the world). Such substances are often subsequently abusively rated as nonflammable but however may develop an explosive atmosphere risk from mixture of their vapors in air at ambient conditions: this was clearly illustrated in this work with ethoxy-nonafluoroethane.

For halogenated liquids, the small volume of the test vessels proposed by the experimental flash point methods associated with the outgassing phenomenon can lead to some of these liquids being claimed as non-flammable ("false negatives") and thus underestimate the risk of explosion and fire that these liquids may present. For example, in the context of storage, we have been able to demonstrate that a sufficiently energetic ignition source can ignite the gas overhead of a liquid classified as non-flammable at much lower temperatures than hydrocarbons classified as highly flammable. It is therefore essential not to rely solely on the flash point to characterize the flammability of these liquids, but also, and more importantly, to assess the lower explosion point and/or the explosive limits.

These substances are considered difficult to ignite because they have a high minimum ignition energy (several joules compared to a few millijoules for hydrocarbons) and a large flame extinction distance characterized by a high maximum experimental safety gap (MESG) ([K. Takizawa, 2015](#), [E. Askar et al, 2018](#), [D.K Kim et al, 2018](#)), to which must be added the influence of ambient air humidity on their combustion. As revealed by this work, complexity of combustion behavior of halogenated substances often requires expert judgement to select appropriate flammability assessment methods of such chemicals among all available testing protocols referenced by applicable regulations and other guiding documents in the field. In addition to the risks associated with their flammability, there is also the problem of toxic risk from the products resulting from their combustion, such as hydrogen fluoride (HF), which is also very corrosive in an aqueous medium) and carbonyl fluoride (COF<sub>2</sub>).

#### Acknowledgment

This work was supported by the French Ministry of Energy Transition.

#### References

3M <https://multimedia.3m.com/mws/media/1998190/3m-novec-7200-engineered-fluid-en.pdf>.

ANSI/ASHRAE Standard 34 (2019), Designation and Safety Classification of Refrigerants.

Askar E., Schröder V., Schmid T., Schwarze M., 2018, Explosion characteristics of mildly flammable refrigerants ignited with high-energy ignition sources in closed systems, *International Journal of Refrigeration*, 90, 249–256, <https://doi.org/10.1016/j.ijrefrig.2018.04.009>.

ASTM E681-09 (2015) Standard Test Method for concentration limits of flammability of chemicals (vapors and gases).

ASTM E502-07 (2013) Standard Test Method for Selection and Use of ASTM Standards for the Determination of Flash Point of Chemicals by Closed Cup Methods.

ASTM E1232 (2019) Standard Test Method for Temperature Limit of Flammability of Chemicals.

Bellair Robert J, Hood L., 2019, Comprehensive evaluation of the flammability and ignitability of HFO-1234ze, Process Safety and Environmental Protection, 132, 273–284, <https://doi.org/10.1016/j.psep.2019.09.033>.

Brandes E., Ural E.A., 2008, Towards a Global Standard for Flammability Determination, Conference: 2008 AIChE Spring National Meeting.

Brandes E., Mitu M., Pawel D, 2007, The lower explosion point—A good measure for explosion prevention: Experiment and calculation for pure compounds and some mixtures, Journal of Loss Prevention in the Process Industries, 20, 536–540.

CEN/TC 305/WG 1 – Potentially explosive atmospheres – Explosion prevention and protection - Test methods for determining the flammability characteristics of substances.

Council Regulation (EC) No 440/2008 of 30 May 2008 laying down test methods pursuant to Regulation (EC) No 1907/2006 of the European Parliament and of the Council on the Registration, Evaluation, Authorisation and Restriction of Chemicals (REACH) (Text with EEA relevance).

Brandes E., Mitu M., Pawel D, 2007, The lower explosion point—A good measure for explosion prevention: Experiment and calculation for pure compounds and some mixtures, Journal of Loss Prevention in the Process Industries, 20, 536–540.

EN 1839 (2017), Determination of the explosion limits and the limiting oxygen concentration (LOC) for flammable gases and vapours.

EN 15794 (2009), Determination of explosion points of flammable liquids.

Fayet G, Tribouilloy B, Rotureau P., 2020, Flash point of binary mixtures of chlorinated hydrocarbons with toluene and their predictability with existing mixing rule, Process Safety Progress, 39: e12127. <https://doi.org/10.1002/>.

Globally Harmonized System of Classification and Labelling of Chemicals (GHS Rev. 9, 2021) <https://unece.org/transport/standards/transport/dangerous-goods/ghs-rev9-2021>

Guidance on the Application of the CLP Criteria Guidance to Regulation (EC) No 1272/2008 on classification, labelling and packaging (CLP) of substances and mixtures Version 5.0 July 2017, [https://echa.europa.eu/documents/10162/23036412/clp\\_en.pdf](https://echa.europa.eu/documents/10162/23036412/clp_en.pdf)

Gorbett G., Kennedy C., Kennedy K., Kennedy P., Kennedy J.A. & Associates, 2004, Outgassing phenomenon in flash point testing for fire safety evaluation, Interflam 2004 Fire Science Engineering Conference Edinburgh (Scotland), vol.1, 725, [https://ssem.eku.edu/sites/ssem.eku.edu/files/gorbett\\_-\\_outgassing\\_phenomena\\_in\\_flash\\_point\\_testing.pdf](https://ssem.eku.edu/sites/ssem.eku.edu/files/gorbett_-_outgassing_phenomena_in_flash_point_testing.pdf).

ISO 10156 (2017) Gas cylinders - Gases and gas mixtures - Determination of fire potential and oxidizing ability for the selection of cylinder valve outlets (ISO 10156:2017),

ISO 2592 (2000), Determination of flash and fire points — Cleveland open cup method

ISO 817 (2014), Refrigerants — Designation and safety classification,

Kim D. K., Sunderland P. B., 2018, Viability of Various Ignition Sources to Ignite A2L Refrigerant Leaks, International Refrigeration and Air Conditioning Conference. Paper 1886, <https://docs.lib.purdue.edu/iracc/1886>.

Kondo S., Takizawa K., Tokuhashi K., 2012, Effects of temperature and humidity on the flammability limits of several 2L refrigerants, Journal of Fluorine Chemistry, 144, 130-136, <https://doi.org/10.1016/j.jfluchem.2012.08.004>.

Kondo S., Takizawa K., Tokuhashi K, Effect of high humidity on flammability property of a few non-flammable refrigerants, Journal of Fluorine Chemistry, 161, 29-33, <https://doi.org/10.1016/j.jfluchem.2014.02.003>.

Molnarne M., Schroeder V., 2017, Flammability of gases in focus of European and US standards. *Journal of Loss Prevention in the Process Industries*, 48, 297-304, <https://doi.org/10.1016/j.jlp.2017.05.012>.

PubChem [Internet]. Bethesda (MD): National Library of Medicine (US), National Center for Biotechnology Information; 2004-. PubChem Compound Summary for CID 206000, Ethyl Perfluorobutyl Ether; [cited 2022 Dec. 14]. Available from: <https://pubchem.ncbi.nlm.nih.gov/compound/Ethyl-Perfluorobutyl-Ether>

PubChem [Internet]. Bethesda (MD): National Library of Medicine (US), National Center for Biotechnology Information; 2004-. PubChem Compound Summary for CID 205999; [cited 2022 Dec. 14]. Available from: <https://pubchem.ncbi.nlm.nih.gov/compound/205999>

Regulation (EC) No 1272/2008 - classification, labelling and packaging of substances and mixtures (CLP) Safety and health at work EU-OSHA (europa.eu)

Richard G., 1994, Refrigerant flammability in large volume vessels flammability criterion determination for ASTM E681 Visual observations / Prepared for: The Air-Conditioning and Refrigeration Technology Institute under ART MCLR Project 665-52400, <https://www.osti.gov/servlets/purl/114574>.

Zhai Z., Yang Z, Feng B., Sun S., 2019, Effect of environmental condition on the flammability limits of two isomers of tetrafluoropropene, *Combustion and Flame*, 207, 295-301 <https://doi.org/10.1016/j.combustflame.2019.05.042>.

Rybicky J, Stevens Jr. 1981, Deceptive closed cup flash points of solvent mixtures containing chlorinated solvents. *Journal of Coatings Technology and Research*, 53,40-42.

Takizawa K, ICR2015 Workshop on Risk Assessment of Mildly Flammable Refrigerants, August 20,2015, 4. Fundamental and Practical Flammability Properties of 2L Refrigerants, <https://www.jsrae.or.jp/committee/binensei/1.4Takizawa.pdf>.

Tribouilloy B., Paillery E., Binotto G., Marlair G., 2022, Flammability of halogenated liquids: Flash points limits, *Chemical Engineering Transactions*, 90, 529-534 DOI:10.3303/CET2290089.

Tsai W-T, 2005, Environmental risk assessment of hydrofluoroethers (HFEs), *Journal of Hazardous Materials*,139, 69–78, doi: 10.1016/j.jhazmat.2006.10.025.

Wu X., Yang Z., Tian T., Quin M., 2014, Experimental research on the flammability characteristics of several binary blends consisting of 1-Chloro-1,1-difluoroethane and extinguishing agents, 92, 680-686, *Process Safety and Environmental Protection*, <http://dx.doi.org/10.1016/j.psep.2013.12.001>.

Yang Z, Liu H., Wu X, 2012, Theoretical and experimental study of the inhibition and inert effect of HFC125, HFC227ea and HFC1311 on the flammability of HFC32, *Process Safety and Environmental Protection*, 90, 311-316, <https://doi.org/10.1016/j.psep.2011.09.009>.

Yang Z, Wu X, Tian T., 2015, Flammability of Trans-1, 3, 3, 3-tetrafluoroprop-1-ene and its binary Blends, *Energy*, 91, 386-392, <http://dx.doi.org/10.1016/j.energy.2015.08.037>.